



# INSTALLATION DRAWING

ACO Pty Ltd  
1300 765 226  
sales@acoaus.com.au

DRG #: IY013

LIPUMAX-G CLASS D (AS 3996) WITH CONCRETE COLLAR  
TO SUIT ENGINEERED SLAB DETAIL

ACO Limited  
0800 448 080  
sales@acoconz.co.nz

Class D (AS 3996) cover and reinforced concrete collar assembly

Inspection opening

Vent

Inspection opening / Trade waste sampling point

Engineered slab detail

Compacted sand/soil sections 300mm

100

Concrete or stabilised sand footing

Angle of excavation to suit site conditions and WHS requirements

150mm

Ø

150mm

Description	Ø
Lipumax-G 3000L	2340
Lipumax-G 4000L	2340
Lipumax-G 5000L	2740

15mm epoxy sealant

Rebate detail

## NOTES:

1. These details only provide a practical reference. ACO recommends designers and installers check local legislative standards and practices, or seek specialised engineering advice.

## Specification Clause

For adequately reinforced concrete slabs, the grease separator shall be ACO Passavant, Lipumax-G below ground grease separator. The grease separator shall be supplied with a Rhinocast® Class D 210 kN (AS 3996) cover and reinforced concrete collar, (part number 142099) and installed in an engineered slab detail.

Grease separator shall be supplied and manufactured by ACO and installed in accordance with local codes and Standards.